



✓	DESCRIPTION	SIZE (H x W x D) (in inches)	CAPACITY (CFM) @ 1.00 IN. W.G.
	01XS-12Z12Z12- <u> </u> -3-C-A-00-0/00 * *	12 x 12 x 11-1/2	230
	01XS-23F11F12- <u> </u> -3-C-A-00-0/00 * *	23-3/8 x 11-3/8 x 11-1/2	460
	01XS-24Z12Z12- <u> </u> -3-C-A-00-0/00 * *	24 x 12 x 11-1/2	500
	01XS-11F23F12- <u> </u> -3-C-A-00-0/00 * *	11-3/8 x 23-3/8 x 11-1/2	460
	01XS-12Z24Z12- <u> </u> -3-C-A-00-0/00 * *	12 x 24 x 11-1/2	500
	01XS-23F23F12- <u> </u> -3-C-A-00-0/00 * *	23-3/8 x 23-3/8 x 11-1/2	1020
	01XS-24Z24Z12- <u> </u> -3-C-A-00-0/00 * *	24 x 24 x 11-1/2	1080

* * : 00 = NO GASKET
 1D = GASKET DOWNSTREAM
 1U = GASKET UPSTREAM
 1B = GASKET BOTH SIDES

MATERIAL NOTES:

- | | |
|---------------------|---|
| 1. FILTER MEDIA: | MICRO-GLASS FIBER / ACRYLIC RESIN BINDER |
| 2. SEPARATOR MAT'L: | CORRUGATED, 0.0012 THICK, 1145 ALUMINUM |
| 3. FRAME MAT'L: | 16 GAUGE ALUMINUM/ZINC ALLOY COATED STEEL |
| 4. SEALANT MAT'L: | FIRE RETARDANT/PHOSPHORUS FREE TWO PART POLYURETHANE |
| 5. GASKET MATERIAL: | 1/4 X 3/4 SCE43 NEOPRENE OR EQUIVALENT CLOSED CELL MATERIAL (IF REQUIRED) |

TESTING NOTES:

1. EACH FILTER SHALL BE TESTED FOR EFFICIENCY IN ACCORDANCE WITH IEST-RP-CC-007.
2. FILTER MEETS IEST-RP-CG001 TYPE A PERFORMANCE LEVEL.

FILTER SPECIFICATIONS:

PLEAT DEPTH (IN): 10-1/2 NOMINAL
 EFFICIENCY: 99.97% MIN vs. 0.3 micron
 MAX. OPERATING TEMP: 200 °F
 MAX. REL HUMIDITY: 99%

UL RATINGS:

1. FILTERS MEET UL-585 AND UL-900 CLASS 2



One North Corporate Drive
 Riverdale, NJ 07457
 973-616-7300, FAX: 973-616-7771

APPROVED BY:	DATE	DRAWN BY:	DATE
		AS	9/5/01

CUSTOMER SERVICE NUMBER

PART DESCRIPTION
 STANDARD ABSOLUTE FILTER SUBMITTAL
 STANDARD CAPACITY, HEPA (99.97%)
 X-SERIES GASKET SEAL

SCALE	PAGE	DWG. NO.
NA	1/1	SAB00001

THIS DOCUMENT AND THE INFORMATION WITHIN IS THE PROPERTY OF CAMFIL FARR. NO DISCLOSURES, REPRODUCTIONS, OR TRANSMITTALS MAY BE MADE WITHOUT AUTHORIZATION.

YOUR APPROVAL OF THIS PRINT AUTHORIZES CAMFIL FARR TO PROCEED WITH MATERIAL PROCUREMENT, TOOLING AND PRODUCT FABRICATION. ANY CHANGES MADE AFTER APPROVAL MAY INCUR FURTHER EXPENSES TO THE CUSTOMER

OK AS IS OK WITH REVISIONS SEND REVISED DWG.

SIGNATURE/DATE _____

FRAME TOLERANCES:

LENGTHS: +0, -1/8"
 DIAGONALS: WITHIN 1/8" TOTAL ALLOWANCE FOR DIAGONALS < 30 in.
 WITHIN 1/4" TOTAL ALLOWANCE FOR DIAGONALS ≥ 30 in.